



PO Box 470 Arundel Qld 4214
info@shortcircuit-electrics.com.au
PH: 0417 718 245
Qld Contractor Lic No: 71938
ABN: 95 747 827 389

Date of Inspection / Test: 15th December
Job No. 18733
Property Address: Villa 62 "Villas Mediterranean" Clear Island Waters

SMOKE ALARM & TEST REPORT DOCUMENTATION OF INSPECTION & COMPLIANCE

All smoke alarms located at the following address have been inspected, cleaned, had a new battery installed and tested for proper operation as recommended by the manufacturer and as required under the *Fire and Rescue Service Amendment Act 2006*.

SMOKE ALARM COMPLIANCE REPORT

10 Year Lithium battery smoke alarms have been installed at the above property

The smoke alarms are approved under AS 3786:2014

The smoke alarm has been tested by means of a built in press to test button

There is least one smoke alarm on every floor level

The property complies with regulations regarding the number of smoke alarms installed

The property complies with regulations regarding the location of smoke alarms installed

I confirm that I have inspected the property and now certify that the above property complies with AS 3786:2014, AS 3000.

Tradesman Name: Joe Gerardis

Signature:

Lic No. 71938