

## CERTIFICATE OF SMOKE ALARM INSTALLATION AND COMPLIANCE

### PROPERTY DETAILS

**Address Line 1:** 25 Cascade Lane  
Fitzgibbon QLD 4018

**Job Number**




3473

**Installer Details:** **Smoke Alarm Services**  
07 5519 9275  
Po Box 365, Hamilton, QLD 4007

**Electrical Contractor Licence No:**  
**85765**

**Installation Date:** **8/7/2022**

### SMOKE ALARMS

Alarm location	Type	Manufacturer	Power	Expiry	Photo
Path of exit	Photoelectric	Emerald	240v (hard wired)	7.32	
Bedroom	Photoelectric	Emerald	10yr Lithium Battery	7.32	
Bedroom	Photoelectric	Emerald	10yr Lithium Battery	7.32	

Path of exit	Photoelectric	Emerald	10yr Lithium Battery	7.32	
--------------	---------------	---------	-------------------------	------	---

---

---

---

---

---

---

## PASS

On the Inspection Date and at the Inspection Address the smoke alarms met the New Requirements.

**This Certifies that the property identified above has been upgraded to meet 2022 QLD Legislation.** *Photoelectric alarms installed to meet AS3786:2014 & all alarms interconnected with every other smoke alarm in the dwelling so all activate together. Smoke alarms installed are either hardwired or powered by a non-removable 10-year battery.*