

# Smoke Alarm Compliance Report

Location: 11 Muir Court, Warner

Contact: Paul Hynes

Date: 30/08/2022

Inspected By: Kerry Crowley

2022 Compliant: **YES**

**Location:** Bed 1 Upstairs


**Power:** 240Volt / 9Volt backup

**Sensor:** Photo-electric

**Replace By:** Jan 2032

**Battery Replaced:** 01/01/2022

**Compliant:** YES



755PSMA4

Photoelectric Smoke Alarm FireTek - Surface mount - 240 V mains-powered - 9V battery backup



**Location:** Bed 2 Upstairs

**Power:** 240Volt / 9Volt backup

**Sensor:** Photo-electric

**Replace By:** Jan 2032

**Battery Replaced:** 01/01/2022

**Compliant:** YES



755PSMA4

Photoelectric Smoke Alarm FireTek - Surface mount - 240 V mains-powered - 9V battery backup



**Location:** Bed 3 Upstairs

**Power:** 240Volt / 9Volt backup

**Sensor:** Photo-electric

**Replace By:** Jan 2032

**Battery Replaced:** 01/01/2022

**Compliant:** YES



755PSMA4

Photoelectric Smoke Alarm FireTek - Surface mount - 240 V mains-powered - 9V battery backup



Location: 11 Muir Court, Warner

06/05/2022

**Location:** Bed 4 Upstairs

**Power:** 240Volt / 9Volt backup

**Sensor:** Photo-electric

**Replace By:** Jan 2032

**Battery Replaced:** 01/01/2022

**Compliant:** YES



**CLIPSAL**  
by Schneider Electric

**755PSMA4**

Photoelectric Smoke Alarm FireTek - Surface mount - 240 V mains-powered - 9V battery backup



**Location:** Upstairs Hall

**Power:** 240Volt / 9Volt backup

**Sensor:** Photo-electric

**Replace By:** Dec 2030

**Battery Replaced:** 01/12/2020

**Interconnect Module**

**Compliant:** YES



**CLIPSAL**  
by Schneider Electric

**755PSMA4**

Photoelectric Smoke Alarm FireTek - Surface mount - 240 V mains-powered - 9V battery backup



**Location:** Downstairs Hall

**Power:** 240Volt / 9Volt backup

**Sensor:** Photo-electric

**Replace By:** Dec 2030

**Battery Replaced:** 01/12/2020

**Interconnect Module**

**Compliant:** YES



**CLIPSAL**  
by Schneider Electric

**755PSMA4**

Photoelectric Smoke Alarm FireTek - Surface mount - 240 V mains-powered - 9V battery backup



Location: 11 Muir Court, Warner

01/09/2022

*This property is compliant on the date this property was inspected, the smoke alarm/s met the requirements of Australian Standard 3786:2014 and the relevant sections of the Building Code of Australia. The property only remains compliant until the next tenancy change or tenancy renewal at which time the property must be re-inspected.*

*We certify that the electrical installation, to the extent that it is affected by the electrical work, has been tested to ensure it is electrically safe and is in accordance with the requirements of the wiring rules and any other standard applying to the electrical installation under the Electrical Safety Regulation 2013*