



**Property Address**

3/20-22 Lawley Street , Kedron QLD 4031

**Generated On:** 22/06/2020

**Technician Name:** Benjamin Lawton

**Date Performed:** 12/06/2020

**Reference Number:** 5048403



**Real Estate Agency**

Image Property Aspley

**Smoke Alarm Safety Service**

Below is a list of the smoke alarms serviced and their individual details.



**COMPLIANT**

This service is compliant with the Building Code of Australia, Australian Standards AS3786 and relevant state based legislation

**Mains 240 Volt (Backup Battery) Smoke Alarm**

✓ **Compliant**

📍 Location/Position: Hallway (Level G)

<b>Manufacturer/Model</b>	Clipsal
<b>Alarm Type</b>	Mains 240 Volt (Backup Battery) Smoke Alarm
<b>Expiry Year</b>	2024
<b>Alarm Replaced/Installed?</b>	No
<b>Required</b>	Yes

🔗 [Click Here To View Full Report](#)

**Mains 240 Volt (Backup Battery) Smoke Alarm**

✓ **Compliant**

📍 Location/Position: Living Room (Level G)

<b>Manufacturer/Model</b>	Clipsal
<b>Alarm Type</b>	Mains 240 Volt (Backup Battery) Smoke Alarm
<b>Expiry Year</b>	2024
<b>Alarm Replaced/Installed?</b>	No
<b>Required</b>	Yes

🔗 [Click Here To View Full Report](#)