





Compliance report

This property *MEETS 2022/2027 Qld Smoke Alarm Compliance*

Required additional works for property to meet QLD 2022/2027 smoke alarm compliance/legislation:	N/A
Safety switch protection at property:	Lights, Power
Safety switch testing:	All safety switches passed testing
Circuit breakers at property:	Lights, Power, Air Con, Stove &/or Oven, Hot Water, Other = Hot Plates
Recommended upgrade to safety switch protection:	

Compliance report

Item	Brand	Expiry date	Location	Work completed	INDIVIDUAL ALARM Meets 2022/2027 compliance	Notes
PE 240v HW-L	Voltex	2031-11-10	Living area ground	Installed new alarm & Tested	YES	
PE 240v HW-L (incl W-B/M)	Voltex	2031-11-10	Hallway L1	Installed new alarm & Tested	YES	
PE WL-L	Voltex	2031-11-10	Bedroom 1 L1	Installed new alarm & Tested	YES	
PE WL-L	Voltex	2031-11-10	Bedroom 2 L1	Installed new alarm & Tested	YES	
PE WL-L	Voltex	2031-11-10	Bedroom 3 L1	Installed new alarm & Tested	YES	

Meets 2022/2027 compliance = alarms/install is compliant with:  Australian Standard AS 3786-2014  Qld Fire & Emergency Services Act 1990 (incl QFES (Domestic Smoke Alarms) Amendment Act 2016)  Qld Building Fire Safety Regulation 2008 (incl Qld Building Fire Safety (Domestic Smoke Alarms) Legislation Amendment Regulation 2016)  Building Code of Australia

KEY

- PE 240v HW-L = Photoelectric 240v 10 Year Lithium Backup Battery; • PE 240v HW-L (incl W-B/M) = Photoelectric 240v 10 Year Lithium Backup Battery (incl Wireless Base/Module); • PE 240v 9v = Photoelectric 240v Photoelectric 9v Battery;
- PE WL-L = Photoelectric Wireless 10 Year Lithium Battery; • PE WL-9v = Photoelectric Wireless 9v Battery; • Tested = Alarm activated; interconnection verified; decibel level registered