

COMPLIANCE OF TESTING AND COMPLIANCE FOR SMOKE ALARMS

Name - Mike Hyslop

Inspection Address: 18 Barnes Drive Buderim QLD 455618 Barnes Drive Buderim
QLD 4556

Test Date: 15/5/2023

Signature:

A handwritten signature in black ink, appearing to be 'MH' or similar, written over a horizontal line.

Inspected by: J&P
Electrical REC
80975

On the Inspection Date and at the Inspection Address, the installation of the **Interconnected** Photoelectric Smoke Alarms **manufactured to AS3786:2014 were inspected and met the relevant requirements** of the current legislation (*Fire and Emergency Services Act 1990 ("The Act") and Building Fire Safety Regulation 2008*).

Note - 3 Existing alarms were tested and passed 7 new battery only 10 year lith have been installed and interconnected

Tested and passed