



21/11/2022

ABN: 40655113376

Contractor Licence: 88880 Electrical Licence: 115468

This certificate is to confirm **71/15 Silvereve Drive, Griffin 4503**

Complies with (Dwelling being leased or sold) smoke alarm legislation dated From 1 January 2017 & new legislation From, 1 January 2022

- i) Be photoelectric (AS 3786-2014); and
 - ii) Not also contain ionisation sensor; and
 - iii) Be less than 10 years old; and
 - iv) Operate when tested; and
 - v) Be interconnected with every other smoke alarm in the dwelling so all activate. Together. Smoke alarms must be installed on each storey.
 - vi) In each bedroom; and
 - vii) In hallways which connect bedrooms and the rest of the dwelling; or
 - viii) If there is no hallway, between the bedrooms and the parts of the storey; and
 - ix) If there are no bedrooms on a storey at least one smoke alarm must be installed in the path of travel.
- to exit the dwelling. Smoke alarms must be hardwired or powered by non-removable 10-year battery,
or a combination of both may be allowed.

For Further information please visit [https: 1/queenslandsmokealarms.com.au/](https://1/queenslandsmokealarms.com.au/)

or please contact us via email on info@staticelectricians.com.au

Regards,

Justin Roy

Static Electrical & Air

Managing Director