

## CERTIFICATE OF:

(Please mark relevant check-box)



**TESTING AND COMPLIANCE** (

Electrical  
Installations



Issued in accordance with s227 of the Electrical Safety Regulation 2013



**TESTING AND SAFETY** (

Electrical  
Equipment



Issued in accordance with s227 of the Electrical Safety Regulation 2013

\* Work performed for:

\* Client: C/O Image Property

\* Address 1/52 Lilly Pilly Crescent

Street

Fitzgibbon

Suburb/town

4018

Postcode

### Works Completed

- \* Installation of 3 x wireless Photoelectric Smoke Alarms
- \* Installation of 1 x 240v Photoelectric Smoke Alarms
- \* All Smoke alarms interconnected
- \* Testing and compliance

### Compliance

- \* All smoke alarm equipment installed:
  - Is manufactured to AS 3786:2014
  - Interconnected as per NCC 3.7.2.2(d)
  - Meets the requirement of the new 2022 Regulations

\* Date of Test 10/04/2024

\* Electrical contractor license number 75497

Name on contractor license Sparks Power Pty Ltd

Electrical contractor phone number 0422 724 793

For **electrical installations**, this certifies that the electrical installation, to the extent it is affected by the electrical work, has been tested to ensure that it is electrically safe and is in accordance with the requirements of the wiring rules and any other standard applying under the Electrical Safety Regulation 2013 to the electrical installation.

For electrical equipment, this certifies that the electrical equipment, to the extent it is affected by the electrical work, is electrically safe

Name Kyle Davis

Person who performed, or person who is responsible for, the electrical work

Signature



Date

12/04/2024

\* Indicates a mandatory field

V4.12-2013