

STATEMENT OF COMPLIANCE

PROPERTY

402/6 Land Street Toowong QLD, 4066 **PROPERTY STATUS**

©Currently Compliant

TYPE OF VISIT

Lease Renewal

INSPECTION DATE

29/01/2024

SMOKE ALARMS SUMMARY:

ALARM 1 - LOUNGE

MAKE: DETECTOR INSPECTOR

MODEL: DI240I POWER: 240vLi RF

TYPE: P/E Interconnected

EXPIRY: 2031 **DB:** 93

ALARM 2 - BEDROOM

MAKE: DETECTOR INSPECTOR

MODEL: DI10YLI POWER: 3vLiRF

TYPE: P/E Interconnected

EXPIRY: 2031 **DB:** 93









All smoke alarms located within the property as detailed above have been cleaned and tested as per manufacturers instructions and been installed in accordance with Australian Standard AS 3786 (2014) Smoke Alarms, Building Code of Australia, Volume 2 Part 3.7.2 of the National Construction code series (BCA) and AS/NZS 3000:2018 Electrical installations.

* Not required for compliance

Where alarm Power is 240v or 240vLi the alarm is mains powered. (Hard Wired). All other alarms are battery powered.

Smoke Alarm Testing Services Pty Ltd.

ABN: 28 132 807 491

SAFETY SWITCH TEST SUMMARY:

3 Safety Switches Present



New/Existing	Make	Model	Test Result
Existing	HAGER	C20	Pass
Existing	HAGER	C20	Pass
Existing	HAGER	C10	Pass

All Safety Switches have been Mechanically Tested and pass a basic mechanical test, to assess they are in working order. No test has been performed to determine the speed at which the device activated.







CORDED WINDOWS SUMMARY:

LOUNGE 2 BEDROOM 1

All Corded Windows within the Property as detailed above are Compliant with Current Legislation and Australian Standards. The Required Clips and Tags have been installed to ensure proper compliance with Current Legislation. Further data is available on the agency portal

Smoke Alarm Testing Services Pty Ltd.

ABN: 28 132 807 491





