

CERTIFICATE OF:

(Please mark relevant check-box)



TESTING AND COMPLIANCE

Issued in accordance with s227 of the Electrical Safety Regulation 2013

(Electrical
Installations)



TESTING AND SAFETY

Issued in accordance with s227 of the Electrical Safety Regulation 2013

(Electrical
Equipment)

* Work performed for:

* Client: C/O Image Property

* Address 62 Warrumbungle Parade

Street

Fitzgibbon

Suburb/town

4018

Postcode

Works Completed

- * Testing of all existing Photoelectric smoke alarms
- * Smoke alarms in date, interconnected and located in compliant locations
- * Testing and compliance

Compliance

- * All smoke alarm equipment installed:
 - Is manufactured to AS 3786:2014
 - Interconnected as per NCC 3.7.2.2(d)
 - Meets the requirement of the new 2022 Regulations

* Date of Test 29/07/2024

* Electrical contractor license number 75497

Name on contractor license Sparks Power Pty Ltd

Electrical contractor phone number 0422 724 793


For **electrical installations**, this certifies that the electrical installation, to the extent it is affected by the electrical work, has been tested to ensure that it is electrically safe and is in accordance with the requirements of the wiring rules and any other standard applying under the Electrical Safety Regulation 2013 to the electrical installation.

For electrical equipment, this certifies that the electrical equipment, to the extent it is affected by the electrical work, is electrically safe

Name Kyle Davis

Person who performed, or person who is responsible for, the electrical work

Signature



Date 29/07/2024

* Indicates a mandatory field

V4.12-2013