

Smoke alarm Compliance Certificate

Compliance Certification Form

For Electrical Installations, this certifies that the Electrical Installation, to the extend it is affected by the Electrical Work, has been tested to ensure that it is electrically safe and is in accordance with the wiring rules and any other standard applying under Electrical Safety Regulations 2013 to the Electrical Installation.

Property Information

Owner Name	Game Plan PM	Property Street Address	18 Robertson Ave, Margate QLD 4019
Owner Telephone Number	0439 736 434	Tenant Name	N/A
Owner Email Address	karen@gameplanpm.com.au	Tenant Email Address	N/A
Owner Postal Address	As above	Tenant Telephone Number	N/A

Smoke Alarm Locations	Date Installed	Alarm Type
Bed 1	09/08/2022	Emerald Planet 10Y Lithium
Bed 2	09/08/2022	Emerald Planet 10Y Lithium
Bed 3	09/08/2022	Emerald Planet 10Y Lithium
Bed 4	09/08/2022	Emerald Planet 10Y Lithium
Level G hall	09/08/2022	Emerald Planet 240V
Level 1 hall	09/08/2022	Emerald Planet 240V

Signature Name JUSTIN SLEEP

Signature of the Person Submitting this Form

Name of the Person Submitting this Form (print)

Date of Signature 09 08 22 Electrical Contractor 89275 License

MM

2022 QUEENSLAND LEGISLATION REQUIREMENTS

The following additional measures, along with related electrical work, must be in place from January 1, 2022 for all Queensland rental properties.

- Smoke alarms must be installed in every bedroom of a home
- All smoke alarms must be powered by either 240v or 10-year lithium battery All smoke alarms must be interconnected
- All smoke alarms must be photoelectric rather than ionisation
- All smoke alarms must meet new Australian Standard 3786:2014 As set out in the Queensland Fire and Emergency Services Act 1990; Building Fire Safety Regulations 2008 and Electrical Safety Act 2002