



Phone: (07) 5408 4066
Email: email@smokealarmed.com.au
Electrical Licence No: 76736
ABN: 95 656 674 655
PO Box 1414, Maroochydore QLD 4558

2022/2027 QLD SMOKE ALARM LEGISLATION COMPLIANCE STATEMENT

JOB # 2125

Property Address: 17 Viewland Drive, Mooloolah Valley QLD 4553

Job Number: 2125

Customer Order Number:

Date of Installation/Inspection: 22/12/2021

Certified By: Luke Pritchard

Electrical License Number: 54476

Number of Smoke Alarms Installed: 7

2022/2027 QLD SMOKE ALARM LEGISLATION CERTIFICATION

We certify that at the time of our site visit, the smoke alarm installation at the above property meets the requirements of the 2022 and 2027 QLD Smoke Alarm Legislation (requiring photoelectric and interconnected smoke alarms in all bedrooms, adjoining hallways and on each level) and the smoke alarms installed are compliant with AS3786:2014. The smoke alarms at this property are safe, working properly and compliant with the Fire and Rescue Service Amendment Act 2006, the Australian Standard 3786:2014, and the relevant sections of the Building Code of Australia.

Disclaimer: Smoke Alarmed can ensure the function of all smoke alarms at the time of the inspection only. We cannot ensure that smoke alarms will not false alarm or fail due to manufacturing issues, interference by any third party, site-specific or environmental factors.

Signed:

Luke Pritchard