



Strybos & Sons Electrical Pty
Ltd
11 - 13 Darling street East
Woodend
QLD 4305

Ph: 07 32018461
Email: info@strybos-
electrician.com.au



TESTING AND COMPLIANCE

(Electrical
installations)

Issued in accordance with s227 of the Electrical Safety Regulation 2013

CERTIFICATE OF:



TESTING AND SAFETY

(Electrical
equipment)

Issued in accordance with s26 of the Electrical Safety Regulation 2013

Tested by: Strybos & Sons Electrical
Compliance Report: SM28053
Issue Date: 22/01/2025

Work performed for:

Name Alix McKendrick

Address 14 Sheppey Place, Yamanto QLD 4305

Smoke Alarm Installation / Equipment Inspected / Tested:

Inspected and cleaned six clipsal firetek RF photoelectric interconnected smoke alarms. Smoke alarms installed in all bedrooms and hallways leading to bedrooms. Tested all alarms on completion - OK.

Smoke alarms comply with January 2022 regulations.

Smoke Alarms Expire/Replace By: 19/08/2029

Date of test 22/1/2025 Electrical Contractors Lic No: 36952

Name on contractor licence Strybos & Sons Electrical Pty Ltd

Electrical contractor phone number 07 32018461

This certifies that the smoke alarms at the above property are operating as intended and are compliant with QFES Amendment Act 2016 (Domestic Smoke Alarms) and Australian Standard AS 3786:2014.

We certify the electrical installation, to the extent that it was affected by the electrical work, is in accordance with the Electrical Safety Regulations 2013.

Legal Disclaimer: Strybos & Sons Electrical takes no legal responsibility if any of the abovementioned items have been tampered with, removed or damaged by the tenant or any other party after the inspection.