



Email: safeandswiftsmokealarms@gmail.com

Phone: 0400256506

ABN: 24224635229

Licence No: 89317

Walter and Regina Thompson

Compliance Report

Property Address: 5 Tancred Ave, Toowoomba, QLD, 4350

Work Order No

Inspected By: Brooke

Inspection Date: 1/07/25

Smoke Alarms

At this inspection, the following smoke alarms were present.

Voltage	Type	Expires	Position	Compliant
240V	Clipsal Photoelectric	2035	Bedroom	Y
240V	Clipsal Photoelectric	2035	Bedroom	Y
240V	Clipsal Photoelectric	2035	Bedroom	Y
240V	Clipsal Photoelectric	2035	Hallway	Y

THIS PROPERTY IS COMPLIANT – SUBJECT TO *

On the date this property was inspected the smoke alarms/s met the requirements of Australian Standard 3786:2014.

We certify that the electrical installation has been tested to ensure it is electrically safe in accordance with the requirements of the wiring rules under the Electrical Safety Regulation 2013. All carried out and tested to Australian standards.

Safety Switch

Installed/ not installed

