

CERTIFICATE OF:

(Please mark relevant check-box)

☒ **TESTING AND COMPLIANCE** (**Electrical installations**)

Issued in accordance with s227 of the Electrical Safety Regulation 2013

☒ **TESTING AND SAFETY** (**Electrical equipment**)

Issued in accordance with s26 of the Electrical Safety Regulation 2013

* Work performed for:

* Name Mr Derek Robson
Title Given name/s Surname

* Address 42 Holmes St
Street
Brighton 4017
Suburb/town Postcode

* Electrical installation / equipment tested (please include site address for electrical installation work if different from above):

Smoke Alarm Compliance - Inspection/Pass

6 x smoke alarms installed - Wireless and smoke alarms with wireless interconnection

Smoke Alarm Installation and testing – The installation methods and equipment selection are compliant to the following regulations and standards. AS/NZS 3000, The Queensland Electrical Safety Regulation 2013, AS 3786:2014

All Smoke alarm equipment supplied and Installed: Meets the requirement of a photoelectric type sensor only. Is manufactured to AS 3786:2014. Where required , hardwired and Interconnected as per NCC3.7.5

Complying with NCC Volume 2 part 3.7.2 AS3786 and the building regulation 2006

* Date of test 23 / 07 / 2025 * Electrical contractor licence number 82598

Name on contractor licence DC Active Electrical Pty Ltd

Electrical contractor phone number 0418758495

For **electrical installations**, this certifies that the electrical installation, to the extent it is affected by the electrical work, has been tested to ensure that it is electrically safe and is in accordance with the requirements of the wiring rules and any other standard applying under the Electrical Safety Regulation 2013 to the electrical installation.

For **electrical equipment**, this certifies that the electrical equipment, to the extent it is affected by the electrical work, is electrically safe.

Name Cameron Rowe

Person who performed, or person who is responsible for, the electrical work

Signature  Date 23 / 07 / 2025

* Indicates a mandatory field

V4.12-2013