



CERTIFICATE OF:

(Please mark relevant check-box)

☒ **TESTING AND COMPLIANCE** (**Electrical installations**)

Issued in accordance with s227 of the Electrical Safety Regulation 2013

☒ **TESTING AND SAFETY** (**Electrical equipment**)

Issued in accordance with s26 of the Electrical Safety Regulation 2013

* Work performed for:

* Name **Mr & Mrs Martin & Kym**

* Address **29 Hill Parade,
Clontarf, Queensland, 4019, Australia**

* Electrical installation / equipment tested (please include site address for electrical installation work if different from above):

Tested and installed 6 x customer supplied photoelectric and interconnected smoke alarms to comply with new queensland 2022 Regulations

Complies with AS3786: 2014

all bedrooms and connecting hallways have compliant smoke alarms at 29 Hill Parade, Clontarf, Queensland, 4019, Australia

* Date of test **23/07/25** * Electrical contractor licence number **1502001**

Name on contractor licence **Bradley Sonter**

Electrical contractor phone number **0452584645**

For **electrical installations**, this certifies that the electrical installation, to the extent it is affected by the electrical work, has been tested to ensure that it is electrically safe and is in accordance with the requirements of the wiring rules and any other standard applying under the Electrical Safety Regulation 2013 to the electrical installation.

For **electrical equipment**, this certifies that the electrical equipment, to the extent it is affected by the electrical work, is electrically safe.

Name **Bradley Sonter**

Person who performed, or person who is responsible for, the electrical work

Signature 

Date **23/07/25**

* Indicates a mandatory field

V4.12-2013