



**Client Name:** Ivy Gray

**Address:** 5 Yaraan Street, Bracken Ridge

**Phone:** 0427136795

**Email:** ivygray0@gmail.com

**Date:** 01/08/2025

## Certificate Of Smoke Alarm Compliance

This certificate confirms that the smoke alarms installed at the premises detailed have been inspected and tested to ensure they are compliant with the Manufactures specifications, AS 3786:2014, and in accordance with the requirements set out in the Fire and Emergency Services Act 1990, the Building Fire Safety Regulation 2008, and the Electrical Safety Regulation 2013. Where smoke alarms are connected to mains power, the associated electrical installation work has been tested to ensure that it is electrically safe and compliant with applicable Australian Standards.



**Brand of Smoke Alarms Installed:** Red Smoke Alarms

**Model of Smoke Alarm Installed:** 1 x RWB2 with 1 X R240 (240V), 5 X R10RF (10 Year Lithium battery).

**Installation Date:** 01/08/2025

**Interconnection Method:** Wirelessly Interconnected

**Description of Alarms Installed:**

- 1 x RWB2 with 1 X R240. Installed to replace an existing 240V smoke alarm in the upstairs hallway. This alarm was programmed to be the master controller for the RF interconnection system.
- 1 X R10RF installed in each upstairs bedroom to replace 9V battery smoke alarms (total alarms 3).
- 1 X R10RF installed in the downstairs bedroom (located at the front of the house).
- 1 X R10RF installed in the downstairs living room.

**Notes:** 240V smoke alarm replaced with 240V RWB2 with 1 X R240.

**Photos:** N/A